



State of New Hampshire  
**DEPARTMENT OF ENVIRONMENTAL SERVICES**

6 Hazen Drive, P.O. Box 95, Concord, NH 03302-0095  
(603) 271-3503 FAX (603) 271-5171



September 30, 2003

**LETTER OF DEFICIENCY #WSEB 03-258**  
**CERTIFIED MAIL 7000 0600 0023 9933 2307**

Gary Marique  
Townhouse Road  
PO Box 830  
Milton, NH 03581

**Subject:** Milton - Public Water System: Mi Te Jo Camping Area (EPA #1587010)

Dear Mr. Marique

The records of the Department of Environmental Services (DES) show that Mi Te Jo Camping Area water system is classified as a public water system (PWS), as defined by RSA 485:1-a. A PWS is defined as any water system serving 15 or more services, or 25 or more people for 60 or more days per year. As such, the water system owner is required to submit samples to the State laboratory or a State-certified laboratory for coliform bacteria analysis in compliance with NH Administrative Rule Env-Ws 325.

DES records show that Standard Maximum Contaminant Level (MCL) violations for total coliform bacteria, as defined in NH Admin. Rule Env-Ws 315.01, have occurred and that letters of violation were issued for the following months:

**August 2003 and September 2003**

DES believes the MCL violations can be corrected and future violations prevented by taking the following actions:

- By October 14, 2003**, retain the services of a qualified water system consultant to address the system's water quality problems relative to the recent bacteriological occurrences; and
  2. **By October 28, 2003**, submit to DES for review a copy of the consultant's report which shall include recommendations to correct the bacteria contamination; and
- By November 11, 2003**, submit to DES for review and approval an implementation schedule which identifies specific dates by which steps to correct the bacteria contamination will be accomplished.

**Letter of Deficiency #WSEB 03-258**

Mi Te Jo Camping Area

September 30, 2003

Page 2 of 2

In the event compliance is not achieved within this period, DES may take further enforcement action, including issuing an order requiring the deficiencies be corrected, initiating an administrative fine proceeding and/or referring the matter to the NH Department of Justice for imposition of appropriate penalties.

The copy of the consultant's written report **and the implementation schedule** as requested above should be addressed as follows:

Anne S. Bailey  
Department of Environmental Services  
Water Supply Engineering Bureau  
6 Hazen Drive, P.O. Box 95  
Concord, NH 03302-0095

Please contact Anne Bailey by phone at (603) 271-0672, or by e-mail at [abailey@des.state.nh.us](mailto:abailey@des.state.nh.us) if you have any questions regarding this letter.

Sincerely,



**COPY**

Anthony P. Giunta, P.G., Administrator  
Water Supply Engineering Bureau

h:\wsebenfmon\enforce\lods\bacteria\2003\1587010 mcl 03-258.doc

cc: Gretchen Rule, DES Legal Unit  
Town of Milton Health Officer  
EPA Region I